

UNION CARBIDE CHEMICALS & PLASTICS COMPANY INC.

Environmental Protection Department

Sistersville, WV

July 16, 1990

Memorandum to: R. E. Tuttle

xc: Paul Shingleton  
E. P. Staff  
Shift Coordinators  
PCB File

Re: PCB Action Report

The following PCB equipment was removed from service and placed into storage for disposal on July 16, 1990:

Plt. ID No. (Tag #)	Manufacturer and Type	Serial Number	Voltage	kVAR/ Unit	Qty. of Fluid (gals)
57	Sprague 2043 PFD	54268	480	20	2.1
54	Sprague 2043 PFD	54322	480	20	2.1
4	Sprague 2043 PFD	54334	480	20	2.1
55	Sprague 2043 PFD	54698	480	20	2.1

Additional comments:

Capacitor 57 was added to drum number 11. This drum now contains two capacitors, tag numbers 52 and 57. Capacitors 54, 4 and 55 were placed into drum number 12. The unloading bay of the Silicon Grinding Building is the current storage area for PCBs.

  
J. A. Selnekovic

JAS/pcb

MPM000820

EPA005158